DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92^{nd} Congress) as amended,

1401 Olive Road, New Haven, MO 63068

MO-0130231

John C. Vatterott Farm, Inc.

Continuing Authority: Address:	Same as above Same as above							
Facility Name: Address:	Cedar Creek Conference Center 1401 Olive Road, New Haven, MO 63068							
Legal Description:	SW ¹ / ₄ , NW ¹ / ₄ , NW ¹ / ₄ , Sec34, T45N, R3W, Franklin County							
Receiving Stream: First Classified Stream and ID: JSGS Basin & Sub-watershed No.:	Tributary to Pin Oak Creek (U) Pin Oak Creek (C) (1663) Missouri River Mainstream- Hermann to St. Louis (10300200-080003)							
s authorized to discharge from the faci as set forth herein:	lity described herein, in accordance with the effluent limitations and monitoring requirements							
	ons/year. discharges under the Missouri Clean Water Law and the National Pollutant Discharge of other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of							
anuary 27, 2006	Donte Childen							
Effective Date	Doyle Childers, Director, Department of Natural Resources Executive Secretary, Clean Water Commission							
March 30, 2009 Expiration Date	Mike Struckhoff, Interim Director, St. Louis Regional Office							

Permit No.

Owner: Address:

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

PAGE NUMBER 2 of 5

PERMIT NUMBER MO-0130231

The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The Interim effluent limitations shall become effective upon issuance and remain in effect until December 30, 2008. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

		INTERIM EFFLUENT LIMITS			MONITORING REQUIREMENTS	
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Outfall #001						
Flow	MGD	*		*	Once/ Month	24 hr. estimate
Biochemical Oxygen Demand ₅	mg/L		65	45	Once/Quarter **	grab
Total Suspended Solids	mg/L		120	80	Once/Quarter **	grab
pH – Units	SU	***		***	Once/ Quarter **	grab
				*		

MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u>; THE FIRST REPORT IS DUE <u>March 28, 2006</u>. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

B. STANDARD CONDITIONS

IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I & III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u>, AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- * Monitoring requirement only. Measure monthly and report quarterly.
- ** Sample once per Quarter during the months of February, May, August and November.
- *** pH is measured in pH units and is not to be averaged. The pH is to be maintained at or above 6.0 pH units.

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS PAGE NUMBER 3 of 5 PERMIT NUMBER MO-0130231

The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective December 31, 2008 and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

OUTE ALL MUMBER AND FEET HENT		FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Outfall #001						
Flow	MGD	*		*	once/month	24 hr. Est.
Biochemical Oxygen Demand ₅	mg/L		45	30	once/quarter **	grab
Total Suspended Solids	mg/L		45	30	once/quarter **	grab
pH – Units***	SU	***		***	once/quarter **	grab

MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u>; THE FIRST REPORT IS DUE <u>January 28, 2009</u>. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

B. STANDARD CONDITIONS

IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I & III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u>, AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- Monitoring requirement only.
- ** Sample once per month during the months of .February, May, August, November.
- *** pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.

C. SPECIAL CONDITIONS

- 1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
 - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

2. All outfalls must be clearly marked in the field.

C. SPECIAL CONDITIONS (continued)

- 3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.
- 4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 μ g/L);
 - (2) Two hundred micrograms per liter (200 μg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 μg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
- (c) That the effluent limit established in part A of the permit will be exceeded.
- 5. Report as no-discharge when a discharge does not occur during the report period.

6. Water Quality Standards

- (a) Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
- (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (5) There shall be no significant human health hazard from incidental contact with the water;
 - (6) There shall be no acute toxicity to livestock or wildlife watering;
 - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.
- 7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities
 - (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
 - (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.

D.SCHEDULE OF COMPLIANCE:

Cedar Creek Conference Center shall upgrades its treatment facility to meet the effluent limitations of 45 mg/L for weekly average and 30 mg/L for monthly average for Biochemical Oxygen Demand (BOD) and Total Suspended Solids as specified by the Water Quality Review Sheet dated April 11, 2005 in accordance with the following schedule.

- 1) By June 28, 2006, submit an engineering report identifying the steps to improve the existing treatment facility or eliminate the discharge.
- 2) By January 28, 2007, submit plans and specifications and an application with appropriate fees for a construction permit to improve the existing system or eliminate the discharge.
- 3) By December 31, 2008, this project must be completed according to the approved plans and specifications and final limits must be met.